



Environmental Health Division • Public Information

County of Ventura • Resource Management Agency • <http://www.ventura.org/rma/envhealth>
800 S. Victoria Ave, Ventura, CA. 93009-1730 • 805 654-2813 • 805 654-2480 Fax

ATTACHMENT F

PRIMARY AND SECONDARY DRINKING WATER STANDARDS SAMPLING INFORMATION

Pursuant to California Health and Safety Code, Section 116385 and the California Code of Regulations, Title 22, section 64432 and 64449, the owner/operator of each domestic water system is required to test for the primary and secondary drinking water standards at a minimum of once every three years. These tests must be performed by a laboratory certified by the California Department of Public Health. The following local laboratories are State certified:

LAB	TELEPHONE NUMBER
BC Laboratory, Bakersfield	661/327-4911
CAPCO, Ventura	805/644-1095
FGL, Santa Paula	805/392-2000
Pat-Chemlab, Moorpark	805/532-0012

Analysis for the primary drinking water standards includes aluminum, antimony arsenic, asbestos, barium, beryllium, cadmium, cyanide, fluoride, mercury, nickel, nitrate (as NO₃), nitrate & nitrite (sum as nitrogen), nitrite (as nitrogen), perchlorate, selenium, and thallium.

Analysis for the secondary drinking water standards includes bicarbonate, carbonate, hydroxide alkalinity, chloride, copper, foaming agents (MBAS), iron, magnesium, pH, sodium, sulfate, specific conductance, total dissolved solids, total hardness, zinc, color, odor, and turbidity.

The lab slip and analysis report must include the name of the sampler, the water system, and location within the system where the sample was taken.